

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-1076:142 Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721  
Contact: Terrill Garland (508) 881-2000 \*Fax (508) 881-1773

**DESIGN:** Model PSD-7152 photoelectric type smoke detector. Refer to listee's data sheet for additional detailed system description and operational considerations.

**RATING:** Electrical: 16.5 - 27.5 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. Suitable for air velocity between 0-300 ft/min for open area protection. May be suitable for use inside duct where air velocity is between 300-4000 ft/min.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as smoke detector for use with Listee's separately listed model Fenwalnet 1000 (CSFM Listing No. 7165-1076:114), 2000 (CSFM Listing No. 7165-1076:141), 4000 (CSFM Listing No. 7165-0074:111) or Pegasys (CSFM Listing No. 7165-1076:146) fire alarm control units.

\*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**